


CERTIFICATE

Certificate holder	Viessmann Werke GmbH & Co. KG Viessmannstr. 1 35108 Allendorf GERMANY
Production facility	Faulquemont
Product	Solar collectors
Type, Model	VITOSOL 100-FM SVKG
Testing basis	DIN EN 12975-1:2011-01 DIN EN ISO 9806:2014-03 Specific CEN Keymark Scheme Rules for Solar Thermal Products Version 28.00 (2015-12)
Mark of conformity	
Registration No.	011-7S2676 F
Valid until	2021-08-31
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

ANNEX

Page 1 of 1

Certificate

011-7S2676 F dated 2016-08-10

Technical Data

See data sheet, part of the test report of 2016-08-09

Note(s):

- The freeze resistance test according to DIN EN ISO 9806, clause 15 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures.

**Testing laboratory/
Inspection body**

TÜV Rheinland Energy GmbH
51101 Köln
GERMANY

Test report(s)

No. 21232812.003 dated 2016-08-09

